



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20182019/13928

Date: 12-12-2023

From:

Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Deys Medical Stores Private Limited
542, Anandapur, EM Bypass, Kolkata-700107

Sub: Renewal of Fire Safety Certificate for the occupancy of an existing G+I storied Factory cum Office under group Industrial Building in the name of "Deys Medical Stores Pvt. Ltd." at premises no. 542, Anandapur, EM Bypass, P.S. Anandapur, Kolkata – 700 107.

This is in reference to your application no. 0125191238701068 dated 17-11-2023 regarding the Renewal of Fire Safety Certificate for the occupancy of an existing G+I storied Factory cum Office under group Industrial Building in the name of "Deys Medical Stores Pvt. Ltd." at premises no. 542, Anandapur, EM Bypass, P.S. Anandapur, Kolkata – 700 107.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free of any type of obstruction and no parking will be allowed on the driveway road.
2. Entrance/Exit gates of the factory building must be free from the any type of obstruction.
3. The interior finish decoration of the Industrial Building shall be made with low flame spread material confirming to the relevant I.S. Specification.
4. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly

maintained.

5. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and duct.
6. A Fire Control Room/security room, including C.C.T.V., Fire Indication Panel will have to be maintained, which will observe & alert all floors of the building.
7. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places in each floor are at strategic location of the building.
8. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to be operate in the event of Fire and Testing.
9. Mock Fire practice and Evacuation Drill shall be performed periodically by the employees and security staff and participants of all the occupants of the factory unit.
10. All Fire Pumps always be kept on auto mode & periodically checked with the help of D.G. set.
11. Electrical ducts shall be sealed vertically and horizontally at each floor level by Fire resisting materials. Electrical safety audit to be conducted at a regular interval.
12. Unauthorized cooking arrangement in any floor of the building using L.P.G., H.S.D., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.
13. A crew of trained Fire Man shall be maintained for safety of the building.
14. First-Aid Fire Fighting system shall be provided as per relevant I.S. specification.
15. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building to keep them in perfectly good working condition at all the times.
16. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
17. Periodical flashing of water from the Landing valves, Hydrant points (external) and Sprinkler pipe lines shall be made to maintain the efficient working performance of the building. A sprinkler test line shall be established for interval testing.
18. D.G. set must be kept in auto mode as providing auto change over switch by which Fire pumps, alarm system, emergency lighting system in staircase, corridor & assembly area etc. shall be started automatically in case of normal power failure.
19. The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
20. The management of the organization/building as the case may be shall maintain the Fire Prevention & Fire Safety

measures in good repair and efficient condition at all time which are installed in the said Industrial building for the use at the time of the Fire or other emergencies.

This Renewal of Fire Safety Certificate is valid for 3 (Three) years and shall have to be renewed every after 3 (Three) years from the date of issue of this letter. Each after 3 (Three) years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the Life and Fire safety arrangement and installation of the said Industrial building.

Signature valid

Digitally Signed:
Name: NIHAR RAMJAN ROY
Date: 12-Dec-2023 11:29
Reason: Approved
Location: West Bengal

Divisional Fire Officer
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/20182019/2928