

GOVERNMENT OF WEST BENGAL
DIRECTORATE OF ELECTRICITY
11, N. S. ROAD, KOLKATA – 700 001

No. AH/ 797 Dated, Kolkata, the 12/05/ 2022.

From :: Dy. Chief Electrical Inspector, Govt. of West Bengal

TO:: Dey's Medical Stores Private Limited
Minerva Graden Complex,
50, Diamond Harbour Road Joka,
Hanspukur, Kolkata-700104, W.B.

Sub : Approval for Replacement for High Voltage installation comprising of
1-100 KVA, 11 /0.433 KV, ONAN Type Transformer, Make-Power Control Nigam
(SL.NO.PCN/900-22) in place of 1-100 KVA, 11/0.415 KV Transformer along with other
old existing HT equipments.

At the above premises as desired.

In your Ref. No. Nil dated 11.05.2022

Dear Sir,

With reference to your application under Regulation 43(3) of the Central Electricity Authority (Measures relating to safety & Electric supply) regulation, 2010 and the inspection by this office on 12.05.2022 I hereby accord approval to your bringing into use the High Voltage Installation mentioned above subject to your compliance with the requirement of the Central Electricity Authority (Measures relating to safety & Electric supply) regulation, 2010 as set out below and any future additions to or alterations in the **11 KV** high voltage circuits or apparatus being notified to the Electrical Inspector, West Bengal and approval in writing obtained from him before the same brought into use.

Encl. : A Bill for Rs.100/- only.

Yours faithfully,


(A. HAQUE)

DY. CHIEF ELECTRICAL INSPECTOR
WEST BENGAL.

**Dy. Chief Electrical Inspector
Govt. of West Bengal**

GOVERNMENT OF WEST BENGAL
DIRECTORATE OF ELECTRICITY
11, N.S.ROAD,KOLKATA-700001.

No. AH/ 94 Dated, Kolkata, the 12.05. 2022.

From :: Dy. Chief Electrical Inspector, West Bengal

To :: **Dey's Medical Stores Private Limited**
Minerva Graden Complex,
50,Diamond Harbour Road Joka,
Hanspukur,Kolkata-700104, W.B.

Bill payable to : THE CHIEF ELECTRICAL INSPECTOR , W.B.
SUPPLY : E.H.V/M.V/H.V.

Date of Inspection / Exam. Or Test of	Fees for the inspection/Examination or Test of	Scale	Rs.	Amount P.
12.05.2022	1-100 KVA, 11 /0.433 KV, ONAN Type Transformer ,Make-Power Control Nigam (SL.NO.PCN/900-22)	B(i)(i)		100.00
Rupees : One hundred Only			Total	100.00

N.B. : The deposit of bill will be made through GRIPS under the Head of Account "0043-00-103-001-16".


DY. CHIEF ELECTRICAL INSPECTOR , WEST BENGAL

Dy. Chief Electrical Inspector
Govt. of West Bengal